



public works

Department:
Public Works
REPUBLIC OF SOUTH AFRICA

COMPLAINT: ID 3215376

**DEPARTMENT OF PUBLIC WORKS: BRYNTIRION ESTATE 896 GOVERNMENT
AVENUE SUBSTATION**

**REPLACEMENT OF STEEL CONTAINED BTU-110 VDC-10A PROTECTION UNIT IN THE
SWITCH GEAR SUBSTATION**

SCOPE OF WORK:

1. Remove existing steel unit for high voltage protection in the substation.
 2. Install new steel unit for high voltage protection in the substation to match the existing
 3. The system must be tested for high voltage and electrical faulty protection for a good working condition
 4. Installation shall be connected with back-up batteries complete unit.
 5. Installation shall be supplied by 16mm 4 core cable from the protection unit to switch gear system in the substation.
 6. Crane truck should be used to transport the unit from the supplier to Bryntirion estate (896 substation)
 7. Certificate of compliance for the installation should be provided on job completion.
 8. Warranty and guarantee should be attached with the submission of the invoice
 9. All damages due to workmanship must be made good to match the existing
 10. Allow cleaning on-site inspection
-

| NO | DESCRIPTION | PLACE | QUANTITY | UNIT PRICE | TOTAL |
|----|---------------------------------------------------------------|-----------------|------------------|------------|-------|
| | Contained BTU-110V-10A batteries protection unit complete set | | 1 | | |
| | 16mm 4core cable 10M | | 1 | | |
| | Crane truck | | Per day | | |
| | | | | | |
| | | QUANTITY | | | |
| | | | | | |
| | FILL IN BELOW WHERE APPLICABLE | | | | |
| | ARTISAN | | /HOUR | | |
| | LABOUR | | /HOUR | | |
| | TRANSPORT | | /KM | | |
| | | | SUB TOTAL | | |
| | | | 14% VAT | | |
| | | | TOTAL | | |

SUMMARY

RESPONSIVENESS CRITERIA:

| | |
|-------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <input checked="" type="checkbox"/> | Only those tenderers who satisfy the eligibility criteria stated in the Tender Data may submit tenders. |
| <input checked="" type="checkbox"/> | Tender offer must be properly received on the tender closing date and time specified on the invitation, fully completed and signed in ink (All as per Standard Conditions of Tender). |
| <input checked="" type="checkbox"/> | Submission of (PA-11): Declaration of Interest. |
| <input checked="" type="checkbox"/> | It is estimated that potentially emerging enterprises should have a CIDB contractor grading designation of 1 EB or EP or higher and satisfy the criteria stated in the Tender Data. |
| <input checked="" type="checkbox"/> | A valid tax clearance certificate for 2024 |
| <input checked="" type="checkbox"/> | Electrical Certificate of Compliance for high or medium voltage |
| <input checked="" type="checkbox"/> | High Voltage Switching Certificate (ORHVS Certificate) |

NAME OF COMPANY.....

TENDERER'S SIGNATURE:

ADDRESS

TEL / FAX DATE: